



Product Service

Compliance Document


No. D 18 04 75386 081

Holder of Certificate: Shenzhen Kstar New Energy Company LimitedThe 9th Floor, R&D Building
Kstar Industrial Park, Guangming Hi-tech Industrial Zone
518107 Shenzhen, Guangdong Province
PEOPLE'S REPUBLIC OF CHINA**Product: Converter (PV grid-interactive inverter)****Model(s): KSG-32K**

Parameters:	PV parameter	
	-Vmax PV:	1000 Vd.c.
	-Isc PV per tracker:	28 Ad.c.
	-MPPT voltage range:	250~950 Vd.c.
	-MPPT tracker number:	3
	AC parameter	
	-Nominal a.c. output voltage:	3/N/PE, 127/220 Va.c.
	-Nominal a.c. output frequency:	60 Hz
	-Maximum continuous a.c. output current:	84 Aa.c.
	-Maximum continuous a.c. output power:	32 kW
	-Power factor range:	0.8 leading~0.8 lagging

Tested according to: IEC 61727(ed.2)
IEC 62116(ed.2)

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. See also notes overleaf.

Test report no.: 64290180163501**Date,** 2018-04-11

(Billy Qiu)


Page 1 of 1